

**REGIONAL WATER TESTING LAB, AMRITSAR**  
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.  
rwtlasr1@gmail.com

To,

Principal Dashmesh International School  
Naraingarh Bypass, Opp. CP-4 Gate Near India Gate, Amritsar

No.: RWTLASR/2526/01571      Dated : 26/03/2026

Subject :            Testing Reports of Water Samples.

Reference:        Your Letter/SRF No. Nil    Dated: 25/03/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 25/03/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A :                Test Report



**Authorized Signatory**  
**For, Regional Water Testing Lab**  
**Amritsar**

**REGIONAL WATER TESTING LAB, AMRITSAR**  
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.  
rwtlasr1@gmail.com



TC-13602

TEST REPORT						
Name & Address of Customer : <b>Principal Dashmesh International School Naraingarh Bypass,Opp.CP-4 Gate Near India Gate,Amritsar</b>			Customer Reference No.		No : Nil Dated : 25/03/2026	
			Sample Submitted by		S.Manider Singh	
			Date of Sample Receipt		25/03/2026	
			Analysis Starting Date		25/03/2026	
			Analysis completion Date		26/03/2026	
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:	TC13602260000150F		Sample Type :		Treated Water	
Test Report No.:	RWTLASR/2526/01571		Date of Issue :		26/03/2026	
Registration no.:	RWTLASR/REG2526/11508		Condition of Sample :		Unsealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		India Gate(RO) / NA	
Village :	Not Mentioned		Habitation :		Not Mentioned	
Block:	Not Mentioned		District :		Amritsar	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.55@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	255	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.62@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	216	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	200	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	40.08	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	24.30	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	29.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

**Mr. Pardeep kumar**  
Quality Manager  
Authorized Signatory  
For,Regional Water Testing Lab  
Amritsar

----- End of the Test Report -----